Models 100X, 101X & 102X

FIBER-COUPLED, ULTRAHIGH-SPEED PHOTODETECTOR MODULES

USER'S MANUAL

HANDLING PRECAUTIONS

The detector is sensitive to electrostatic discharges and could be permanently damaged if subjected even to small discharges. Prior to handling, or making connections, be sure to ground yourself adequately. A ground strap provides the most effective grounding and minimizes the likelihood of electrostatic discharge.

Do not over-torque the microwave K-connector. Excessive torque can damage connectors.

Make sure the optical connector is clean and undamaged before connecting to the detector module.

QUICK START

The Models 101X and 102X are high-speed InGaAs photodetector modules for detection of light of wavelengths 950 to 1650 nm. The Models 100X are GaAs photodetector modules for detection of light of wavelengths 400 to 900 nm. All are 50-Ω terminated, except the 1001 and 1004 which have 100-Ω terminations. An internal battery and bias circuitry make the modules self-contained so that no additional power supplies or bias circuitry are needed. To operate the modules, follow these instructions:

1. **Take proper precautions to avoid electrostatic damage to the photodiode.** (See the Handling Precautions above.)
2. Remove module from its case.
3. Turn on power using the "Off/On" switch.

【ν】 Is a registered trademark of New Focus, Inc.

(Perform steps 4, 5 and 6 if using the detector for the first time or you wish to check the battery and DC offset.)

4. Connect a voltmeter to the "Bias Monitor" SMA connector.
5. Press "Batt Chk" button. The voltage should be 3.5 to 5 V (-3.5 to -5 V) for the 101X and 102X (100X) detectors.
6. Release the "Batt Chk" button. Without an optical input, the voltage should be less than 10 mV.
7. Connect the photodetector module to your measurement instrument, being careful not to over-torque the K-connector. The instrument must have a 50-**Ω** input impedance.
8. **Check that the optical power emerging from your fiber is below the Max. Pulse Power or cw Saturation Power as appropriate** (see the Detector Characteristics section of this manual) to ensure detector linearity and to avoid detector damage.
9. Connect your optical fiber to the connector on the detector module.
10. When finished using the module, turn off power to preserve battery life.

If any of these steps present problems or you would like more information, please consult the remainder of this manual.

[ν] INTRODUCTION

Ultrahigh-speed measurements are easy with the series 100X, 101X, and 102X ultrahigh-speed photodetector modules. These modules convert your optical signals to electronic signals, in effect, giving every high-speed/high-frequency instrument in your lab an optical input. The modules are connected directly to the test instrument or amplifier, eliminating the need for coaxial cables following the photodetector which can seriously distort picosecond pulses and attenuate microwave signals. The optical signal is delivered to the Schottky photodiode in the module through a single-mode optical fiber. Moreover, the photodiode bias circuit and battery are self-contained, eliminating the hassle of external power supplies and expensive bias networks and reducing the possibility of photodiode damage due to overvoltage.

New Focus offers a total of eight models, allowing you to match your wavelength of interest and the connector style of your instrumentation. The Models 101X and 102X are high-speed InGaAs photodetector modules for detection of light of wavelengths 950 to 1650 nm. Models 101X are optimized for a flat frequency response, and the Models 102X are optimized for an impulse response with minimal ringing. Both types are 50-Ω terminated to reduce reflections in 50-Ω systems and to make them compatible with 50-Ω receiver filters. The Models 100X are ultrahigh-speed GaAs photodetector modules for detection of light of wavelengths 400 to 900 nm. These detectors offer at once both broadband and minimal-ringing responses and are terminated in either 50-Ω or 100-Ω. All detectors are available with either FC or ST connectors with single-mode input. Each models' characteristics are listed and their responsivity-vs.-wavelength curves are shown in the Detector Characteristics section of this manual.

Checking the Battery and Offset Voltage:

The battery and offset voltage should be checked regularly to ensure proper functioning of the detector.

1. Turn on the module using the power switch.
2. Connect the "Bias Monitor" port to a voltmeter.
3. Press and hold the "Batt Chk" button and observe the bias monitor output. The photodiode bias voltage is momentarily applied to the "Bias Monitor" SMA connector. A reading of -4.5 V for Models 100X or 5 V for Models 101X and 102X on this connector is typical with a new battery; the battery should be replaced when the voltage reaches -3.5 V for the 100X series or 3.5 V for the 101X and 102X series.
4. Release the "Batt Chk" button and observe the voltage level on the voltmeter. Without an optical input, this voltage is the DC offset plus dark current. This "dark voltage" should be less than 10 mV.
5. If needed, keep the voltmeter connected to the module while you optimize coupling to the fiber.

Making the Microwave Connection:

Connect the microwave output connector of the photodetector module to a 50-Ω input test instrument such as an oscilloscope or spectrum analyzer, or other 50-Ω load using the proper torque. To avoid connector damage and signal distortion, be sure that the instrument you intend to connect to the module has a compatible connector. See Appendix 2: Using the Correct Microwave Connector for a list of connector compatibilities.

Aligning the Photodetector to the Optical Input:

To avoid signal distortion, the optical fiber used to deliver the optical signal to the photodetector module should be single mode at the operating wavelength and the cable length should be no longer than necessary.

[ν] OPERATION

1. If you do not currently have an ST- or FC-terminated optical fiber, use either a pigtail assembly or a fiber collimator (see Table 1), and align the fiber so that light exits the output fiber connector. With a pigtail assembly, use a fiber aligner such as the Model 9091 and its accessories; with a collimator, use the Model 9854 Opti-Claw or the Model 9016 tiny fiber positioner.
2. Measure the power in the fiber prior to connection to the module to be sure it is within the safe operating range (see the Detector Characteristics section of this manual). The Models 20X1-FC and 20X1-ST photoreceivers are useful for this purpose and have the sensitivity to aid in fiber alignment.
3. Connect the fiber-optic cable to the fiber-optic input on the detector module. The Bias Monitor voltage may be used to optimize coupling to the fiber.

Table 1 Fiber-optic cable assembly selection table.

Optical Input	**Fiber Assembly Required**
< 2 mm diameter collimated beam at:	
830 nm wavelength	Model 1233 collimator-FC (2 meters) for 1004, 1006
1.3 µm wavelength	Model 1237 collimator-FC (2 meters) for 1014, 1024
1.55 µm wavelength	Model 1238 collimator-FC (2 meters) for 1014, 1024
Other wavelengths and beam types	
600 to 900 nm wavelength	Model 1223 pigtail-FC assembly (2 meters) for 1004, 1006
1.1 to 1.6 µm wavelength	Model 1232 pigtail-FC assembly (2 meters) for 1014, 1024
Patch Cable	
1.1 to 1.6 µm wavelength	Model 1222 ST-FC (2 meters)
	These assemblies are available from New Focus. Collimators require an Opti-Claw tilt-mount such as the Model 9854. Pigtail assemblies require a fiber aligner such as the Model 9091.

Replacing the battery:

1. Turn off the module and remove the two screws on the back panel with a Phillips screwdriver. (See Fig. 1.)
2. Remove the back panel and replace the battery.
3. Replace the back panel.
4. Check the battery level as described above.

Fig. 1 Front, side, and rear views of the Models 100X, 101X, and 102X fiber-coupled photodetector modules.



APPENDICES

APPENDIX 1: USING AN OPTICAL FIBER

Single mode optical fiber can provide low loss and low distortion if attention is paid to a few important details. First, if more than one mode is allowed to propagate in a step-index fiber, the bandwidth will be degraded to approximately $f_{3\text{-dB}} = [cn] / [2L(NA)^2]$, where c is the speed of light in free space, n is the index of the core, L is the length of the fiber, and NA is the numerical aperture of the fiber. Modal distortion can be eliminated by using a fiber with a core small enough that only a single mode will propagate. In this case, the bandwidth of the fiber will be limited by material dispersion which is a property of the glass used in the fiber core. In this limit, the bandwidth is approximately* $f_{3\text{-dB}} = 1 / [2LM\Delta\lambda]$, where L is the fiber length in kilometers, M is the material dispersion in ps/(nm × km), and $\Delta\lambda$ is the line width of the optical source in nm. This bandwidth limitation can be ignored for glass fibers less than 10 meters in length, but can be serious for longer fibers and spectrally broad sources.

*Palais, C.J., Fiber Optic Communications, Prentice-Hall, Inc., Englewood Cliffs, NY., 1984

APPENDIX 2: USING THE CORRECT MICROWAVE CONNECTOR

The performance you obtain from the Models 100X, 101X and 102X photodetector modules will depend largely on the instrument you use to measure its microwave output and how the connection is made to this instrument. The male connector of the photodetector module should be connected directly to the female connector of the instrument. If an intervening coaxial cable is used, care must be exercised in selecting a cable that has sufficiently low loss in the frequency range of interest. Even if a coaxial cable is not used, performance can be degraded if an improper adapter is chosen for mating to the instrument. Common SMA connectors, for example, are intended for use to only 18 GHz. Table 2 is a list of a few connectors and the frequency range in which they may be used.

Table 2. Common RF connectors and the corresponding frequency ranges in which they are useful.

Connector Type	Frequency Range	Compatibility
BNC	DC-2 GHz	—
SMA	DC-18 GHz	Wiltron K, 3.5 mm
3.5 mm	DC-34 GHz	SMA, Wiltron K
Wiltron K	DC-40 GHz	SMA, 3.5 mm
2.4 mm	DC-55 GHz	Wiltron V
Wiltron V	DC-65 GHz	2.4 mm

New Focus also offers the following products:
Model 1224 Female-V to Male-K
Model 1225 Male-SMA to Female-BNC
Model 1226 Female-SMA to Male-BNC
Model 1227 40-GHz Flex Cable, Female-K to Male-K

APPENDIX 3: INSIDE THE PHOTODETECTOR MODULE

Inside the photodetector module is a gold-plated microwave housing that contains the high-frequency circuitry. This housing is bolted to a printed-circuit board which regulates the bias for the photodiode and amplifies the DC photocurrent for the monitor port. The optical signal is brought from the front-panel connector to the microwave housing with a <0.2-meter, 9-µm core fiber. Although the material and modal dispersion per unit length of this fiber can be high at certain wavelengths, there is no degradation in frequency response since the fiber is less than 0.2 meters long. The fiber is protected by a sheet metal flange to prevent damage while changing the battery. A simplified schematic is provided in Fig. 2 for your reference.

Fig. 2a. Simplified schematic diagram of the 100X series photodetector modules.



Fig. 2b. Simplified schematic diagram of the 101X and 102X series photodetector modules.



TROUBLESHOOTING

Several problems which can arise with the detector modules and procedures to check for them are outlined below.

Problems:

Damaged photodiode/Excessive offset voltage: The photodiode can be damaged by electrostatic discharge or excessive optical power, and both causes lead to an increased dark (or offset) voltage. A damaged photodiode can result in a degraded responsivity and frequency/impulse response. See DC Offset Voltage below.

Low bias voltage: If the photodiode bias voltage is too low, the frequency/impulse response of the detector will degrade, as will the responsivity. See Checking the Battery below.

Dirty fiber-optic connector: A dirty fiber-optic connector can cause an apparent degradation of responsivity. See Basic Optical Test below.

Test Procedures and Solutions:

DC Offset Voltage

With no light on the photodetector, turn the detector on and use a voltmeter to measure the Bias Monitor output voltage. This voltage is the DC offset plus dark current. If the output is >10 mV, then the detector is probably damaged and will need to be returned to New Focus.

Checking the Battery

1. Turn on the module using the power switch.
2. Connect the "Bias Monitor" port to a voltmeter.
3. Press and hold the "Batt Chk" button and observe the bias monitor output. The photodiode bias voltage is momentarily applied to the "Bias Monitor" SMA connector. A reading of -4.5 V for Models 100X or 5 V for Models 101X and 102X on this connector is typical with a new battery; the battery should be replaced when the voltage reaches -3.5 V for the 100X series or 3.5 V for the 101X and 102X series.

[v] TROUBLESHOOTING

Replacing the Battery

1. Turn off the module and remove the two screws on the back panel with a Phillips screwdriver. (See Fig. 1.)
2. Remove the back panel and replace the battery.
3. Replace the back panel.
4. Check the battery level as described above.

Basic Optical Test

To quickly test whether a photodetector appears to be working, you can perform a simple DC optical test:

1. Turn the detector on.
2. Using a voltmeter or oscilloscope, measure the output voltage from the Bias Monitor on the front panel. (With no light on the detector, the Bias Monitor voltage should be <10 mV.)
3. Couple some CW light into the photodetector.
4. With the voltmeter or oscilloscope, you should observe a DC output voltage. If you know the optical power and wavelength, you can calculate the expected output voltage (V_{out}) using the expression: $V_{out} = P_{in} \cdot R \cdot G$, where P_{in} is the input optical power (watts), R is the photodetector's responsivity (A/W), and G is the amplifier's transimpedance gain (V/A). The gain of the bias monitor port is 1000 V/A.

If the output voltage appears to be low, then the fiber connector might be dirty. If a dirty connector is suspected, see Cleaning the Fiber Connector below.

Cleaning the Fiber Connector

The high-speed photodetectors have an internal fiber connector and a fiber pigtail that brings the input light to the detector. If the fiber connector is dirty, this can block the input light so that light

sent into the detector will produce little or no output voltage. Note also that if the fiber types are not compatible (single-mode with multi-mode, and vice-versa), this can also be the cause of a very low output voltage.

To clean the fiber:

1. Turn off the module.
2. Blow filtered air or another inert gas (such as nitrogen) into the input fiber connector. This will help to remove any dust or dirt particles that might be blocking the input light.

If more cleaning is needed, proceed with steps 3-8.

3. Wear a grounding strap.

4. Remove the two screws on the back panel with a Phillips screwdriver. Remove the back panel.
5. Remove the two screws on the bottom of the detector using an Allen key (1/16" or 1.5-mm), and carefully slide the detector housing off.

Steps 6-8: Be extremely careful not to pull on the fiber. Stress applied to the fiber where it attaches to the microwave housing can cause the fiber to misalign from the photodiode, resulting in degraded detector performance.

6. Carefully disconnect the fiber connector from the fiber receptacle attached to the front panel of the detector.
7. The front surface of the fiber can be cleaned using acetone or alcohol and lens tissue.
8. Carefully reconnect the fiber to the front panel receptacle, re-install the detector housing (be careful not to pinch or damage the fiber), and re-install the back panel.

DETECTOR CHARACTERISTICS

Model #	1001(1004)	1002(1006)	1011(1014)	1021(1024)
Wavelength Range	400-900 nm	400-900 nm	950-1650 nm	950-1650 nm
Max. Full Width at Half Maximum	•	•	•	12 ps
Min. 3-dB Bandwidth (Electrical)	35 GHz	50 GHz	40 GHz	•
Conversion Gain at Peak λ	6.6 V/W	5 V/W	10 V/W	10 V/W
Responsivity at Peak λ	0.2 A/W	0.2 A/W	0.4 A/W	0.4 A/W
Output Impedance	100 Ω	50 Ω	50 Ω	50 Ω
Min. NEP	70 pW/√Hz	90 pW/√Hz	45 pW/√Hz	45 pW/√Hz
cw Saturation Power	5 mW	5 mW	1 mW	1 mW
Max. Pulse Power	200 mW	200 mW	100 mW	100 mW
Detector Material	GaAs	GaAs	InGaAs	InGaAs
Detector Type	Schottky	Schottky	Schottky	Schottky
Detector Diameter	12 μm	12 μm	12 μm	12 μm
Power Requirements	9-V battery	9-V battery	9-V battery	9-V battery
Optical Input (single mode fiber)	ST(FC)	ST(FC)	ST(FC)	ST(FC)
Electrical Output	Wiltron K	Wiltron V	Wiltron K	Wiltron K
Bias Monitor:				
DC Gain	1 mV/μA	1 mV/μA	1 mV/μA	1 mV/μA
DC Offset	<10 mV	<10 mV	<10 mV	<10 mV
Output Impedance	1 kΩ	1 kΩ	1 kΩ	1 kΩ
Bandwidth	50 kHz	50 kHz	50 kHz	50 kHz

Fig 3. Responsivity vs. wavelength for a) Models 100X and b) Models 101X and 102X.



WARRANTY, SERVICE & SUPPORT

New Focus, Inc. guarantees its products to be free of defects for one year from the date of shipment. This is in lieu of all other guarantees, expressed or implied, and does not cover incidental or consequential loss.

TECHNICAL SERVICE AND SUPPORT

In the event that your photodetector malfunctions or becomes damaged, please contact New Focus for a return authorization number and instructions on shipping the unit back for evaluation and repair. Information and advice about the operation of any New Focus product is available from our technical support engineers. For technical assistance or to discuss a repair, you can reach us at:

NEW FOCUS, Inc.
2630 Walsh Avenue
Santa Clara, CA
95051-0905 USA

Phone: (408) 980-8088
Fax: (408) 980-8883
Email: Contact@NewFocus.com
Internet: www.NewFocus.com

{v} TABLE OF CONTENTS

HANDLING PRECAUTIONS 2

QUICK START 2

INTRODUCTION 4

OPERATION 5

APPENDIX 1: USING AN OPTICAL FIBER 9

APPENDIX 2: USING THE CORRECT MICROWAVE CONNECTOR.....10

APPENDIX 3: INSIDE THE PHOTODETECTOR MODULE 11

TROUBLESHOOTING.....13

DETECTOR CHARACTERISTICS 16

WARRANTY, SERVICE & SUPPORT 18